STATIONARY SOURCE PERMIT TO OPERATE

(5 STACK version)

This permit supersedes/replaces your permit dated June 1, 2007

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

Mirant Potomac River LLC 8301 Professional Place Suite 230 Landover, MD 20785 Registration No.: 70228

is authorized to operate

an electricity generating facility

located at

1400 North Royal Street Alexandria, VA 22314

in accordance with the Conditions of this permit.

Approved on **DRAFT**.

Director, Department of Environmental Quality

Permit consists of 24 pages. Permit Conditions 1 to 48.

INTRODUCTION

This permit approval is based on the results of air dispersion modeling conducted using a protocol approved by the Department of Environmental Quality (DEQ) to ensure that the Mirant Potomac River Generating Station (PRGS) does not contribute to a modeled exceedance of the National Ambient Air Quality Standards (NAAQS). Any changes to an existing facility which alter the impact of the facility on air quality may require a permit. Failure to obtain such a permit prior to construction may result in an enforcement action. In addition, this facility may be subject to additional applicable requirements not listed in this permit.

Words or terms used in this permit shall have meanings as provided in 9 VAC 5-10-20 and 9 VAC 5-80-810 of the State Air Pollution Control Board's (Board) Regulations for the Control and Abatement of Air Pollution (Regulations). The regulatory reference or authority for each condition is listed in parentheses () after each condition.

Annual requirements to fulfill legal obligations to maintain current stationary source emissions data will necessitate a prompt response by the permittee to requests by the DEQ or the Board for information to include, as appropriate: process and production data; changes in control equipment; and operating schedules. Such requests for information from the DEQ will either be in writing or by personal contact.

The availability of information submitted to the DEQ or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the Board) of the Code of Virginia, and 9 VAC 5-170-60 of the State Air Pollution Control Board's Regulations for the Control and Abatement of Air Pollution. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

PROCESS REQUIREMENTS

1. **Equipment List** - Equipment at this facility consists of the following:

Equipment to be	Equipment to be modified			
Reference No.	Equipment Description	Maximum Rated Capacity (as calculated from CEM data)	Manufactured Date	
C1 Cycling Unit	Combustion Engineering, natural circulation, tangentially coal-fired with superheater and economizer with low NOx burners.	1053 MMBtu/hr	1949	
C2 Cycling Unit	Combustion Engineering, natural circulation, tangentially coal-fired with superheater and economizer with low NOx burners.	1029 MMBtu/hr	1950	
C3 Base Unit	Combustion Engineering, controlled circulation, tangentially coal-fired with superheater, single air reheater and economizer with low NOx burners and over fired air.	1018 MMBtu/hr	1954	
C4 Base Unit	Combustion Engineering, controlled circulation, tangentially coal-fired with superheater, single air reheater and	1087 MMBtu/hr	1956	

	economizer with low NOx burners and over fired air.		
C5 Base Unit	Combustion Engineering, controlled circulation, tangentially coal-fired with superheater, single air reheater and economizer with low NOx burners and over fired air.	1107 MMBtu/hr	1957
Reference No.	Equipment Description	Maximum Rated Capacity	Manufactured Date
Ash Silos	Two (2) fly ash silos and one (1) bottom ash silo	480 tons per day	n/a
Ash Loader	Fly ash and bottom ash truck loading from silos and ash truck roadway dust	880 tons per day	n/a
Coal Handling	Coal pile wind erosion, coal stack-out conveyor system, coal railcar dumper	711,836 tons per year	n/a
Sodium	Pneumatic upload system, full enclosure		
sesquicarbonate Handling Dry Sorbent		n/a	n/a

Note: The maximum rated capacity depicted in this table is the calculated value used for modeling and determined using Part 75 Appendix F.

Specifications included in the permit under this Condition are for informational purposes only and do not form enforceable terms or conditions of the permit. (9 VAC 5-80-830)

- 2. Nitrogen Oxides (NO_x) Emission Controls NO_x emissions from boilers C1 and C2 shall be controlled by the use of low NO_x burners. The low NOx burners shall be provided with adequate access for inspection and shall be in operation when the boilers are operating. (9 VAC 5-80-850 F)
- 3. Nitrogen Oxides (NO_x) Emission Controls NO_x emissions from boilers C3, C4 and C5 shall be controlled by the use of low NO_x burners and separated over-fire air (SOFA). The low NO_x burners and SOFA systems shall be provided with adequate access for inspection and shall be in operation when the boilers are operating. (9 VAC 5-80-850 F)
- 4. Sulfur Dioxide (SO₂) and Acid Gas Emission Controls SO₂ emissions from boilers C1, C2, C3, C4 and C5 shall be controlled by the use of low sulfur coal and dry sorbent injection (Sodium sesquicarbonate (or DEQ approved equivalent). An alternate dry sorbent may be used for SO₂ emission controls after it has been demonstrated to the satisfaction of the DEO that the alternate dry sorbent will reduce SO₂ emissions and acid gas emissions (HCl and HF) at an emission rate equivalent to or greater than those produced by sodium sesquicarbonate and that meets the emissions limits in this permit. The dry sorbent injection system shall be provided with adequate access for inspection. Dry sorbent (Sodium sesquicarbonate or equivalent) shall be injected anytime a boiler is operating on coal.

- 5. **Particulate Matter (PM) Emission Controls** Particulate emissions from boilers C1, C2, C3, C4 and C5 shall each be controlled by hot side electrostatic precipitator followed in series by cold side electrostatic precipitator, designated as HSEP1, HSEP2, HSEP3, HSEP4 and HSEP5 and CSEP1, CSEP2, CSEP3, CSEP4 and CSEP5, and dry sorbent injection (Sodium sesquicarbonate or equivalent) respectively. The electrostatic precipitators shall be provided with adequate access for inspection and shall be in operation when the connected boiler is operating. (9 VAC 5-80-850 F)
- 6. **Particulate Matter (PM) Emission Controls** Particulate emissions from the two (2) fly ash silos shall be controlled by baghouse fabric filters and by routing the baghouse fabric filter exhausts to the boiler C1 hot side electrostatic precipitator. The baghouse fabric filters shall be provided with adequate access for inspection and shall be in operation when the fly ash silos are being utilized (filling and unloading). (9 VAC 5-80-850 F)
- 7. **Particulate Matter (PM) Emission Controls** Particulate emissions from the bottom ash silo shall be controlled by a baghouse fabric filter. The baghouse fabric filter shall be provided with adequate access for inspection and shall be in operation when the bottom ash silo is being utilized (filling and unloading).

 (9 VAC 5-80-850 F)
- 8. **Particulate Matter (PM) Emission Controls** Particulate emissions from fly ash and bottom ash transfer from the ash silos to trucks shall be controlled by partial enclosure and wet suppression within the loading chute and water fogging within the enclosure. The partial enclosure system shall be provided with adequate access for inspection and shall be utilized whenever fly ash and bottom ash loading from the silos to trucks is occurring. (9 VAC 5-80-850 F)
- 9. Particulate Matter (PM) Emission Controls Coal Handling Particulate emissions from the coal pile (via wind erosion) shall be controlled by the installation of a wind screen and use of a surfactant during loading of the coal pile. Particulate emissions from the coal stack-out conveyor system shall be controlled by the use of an enclosed conveyor and the installation of a telescopic chute. Particulate emissions from coal railcar dumping shall be controlled by partial enclosure with heavy duty curtains and by the use of water fogging spray header. All controls shall be functional and in operation whenever coal pile and/or railcar dumping activities are in operation. (9 VAC 5-80-850 F)
- 10. **Particulate Matter (PM) Emission Controls** Particulate emissions from dry sorbent (Sodium sesquicarbonate or equivalent) handling shall be controlled by use of a fully enclosed pneumatic conveying system. The conveying system shall be for transferring dry sorbent from the rail cars to the silos and from the silos to the injection point into the boiler exhaust ducting. (9 VAC 5-80-850)
- 11. **Electrostatic Precipitator (ESP) Control Efficiency** The electrostatic precipitators (HSEP1 + CSEP1, HSEP2 + CSEP2, HSEP3 + CSEP3, HSEP4 + CSEP4, and HSEP5 + CSEP5) shall achieve an overall control efficiency for all PM that demonstrates compliance with the emission limitations

in this permit and shall be demonstrated as required in conditions 33 and 35. Continued control effectiveness shall be determined using daily readings of secondary voltage and current. These readings shall be compared to those readings taken during the compliance demonstration stack test to demonstrate continued control efficiency. (9 VAC 5-80-850 F)

- 12. **Fugitive Dust and Fugitive Emission Controls** Fugitive emission controls shall include but are not limited to the following, or equivalent, as approved by DEQ:
 - a. Use of water or chemicals for control of dust in the demolition of existing buildings or structures, construction operations, grading of roads, or clearing of land.
 - b. Application of asphalt, water, or suitable chemicals on dirt roads, materials stockpiles, and other surfaces which may create airborne dust; the paving of roadways and the maintaining of the roadways in a clean condition.
 - c. Open equipment for conveying or transporting materials likely to create objectionable air pollution when airborne shall be covered or treated in an equally effective manner at all times when in motion.
 - d. Prompt removal of spilled or tracked dirt or other materials from paved streets and of dried sediments resulting from soil erosion.
 - e. Reasonable precautions shall be taken to prevent deposition of dirt on public roads and subsequent dust emissions. Trucks leaving the site shall have clean wheels achieved by use of a wheel washer or equivalent.
 - (9 VAC 5-40-90 and 9 VAC 5-80-850)
- 13. Monitoring Continuous Opacity Monitoring Systems (COMS) Continuous Opacity Monitoring Systems meeting the design specifications of 40 CFR Part 60, Appendix B shall be installed to measure and record the opacity of emissions from the stacks of boilers C1, C2, C3, C4 and C5. Except where otherwise indicated in this permit, the COMS shall be installed, calibrated, maintained and operated in accordance with the requirements of 40 CFR 60.13 and Appendix B or DEQ approved procedures which are equivalent to the requirements of 40 CFR 60.13 and Appendix B. Data shall be reduced to six minute averages. The COMS may be used to satisfy the visible emission evaluation requirement in lieu of 40 CFR, Part 60, Appendix A, Method 9. In the event that the COMS is used in lieu of a 40 CFR, Part 60 Appendix A Method 9 evaluation, the reported data shall include averages of all six minute continuous periods within the reported period and within the duration of any mass emission performance tests being conducted. It is the responsibility of the permittee to demonstrate that the monitoring system has met the requirements of the applicable performance specification as defined in 40 CFR Part 60, Appendix B, that the monitoring system has been properly maintained and operated, and that the resulting data has not been altered in any way. In the event that the COMS data indicates compliance for a period during which Method 9 data indicates non-compliance, the Method 9 data may be used to determine compliance with the visible emission limit.

(9 VAC 5 40-20 A, 9 VAC 5-40-40, 9 VAC 5-80-890 and § 10.1-1307.3.B)

14. **Monitoring - Continuous Emission Monitoring Systems (CEMS) -** CEMS meeting the design specifications of 40 CFR Part 60, Appendix B and 40 CFR Part 75 shall be installed to measure and record, SO₂, and NO_x (as ppmv corrected to 7% O₂ or 12% CO₂), volumetric flow rate, and CO₂ or

O₂ and PM from the stacks of boilers C1, C2, C3, C4 and C5. The requirement to install and operate a PM CEMS is deferred until such time that all performance specifications and operations requirements applicable to PM CEMS have been promulgated by EPA, become effective and DEQ has notified the permittee in writing of a deadline for installing the PM CEMS. The permittee shall inform the Air Compliance Manager of the Northern Regional Office (NRO) as to which diluent will be used to normalize the SO₂, and NO_x Before changing the diluent to be used for normalization, the permittee shall justify in writing to the Air Compliance Manager of the NRO the reasons for the change in diluent. Except where otherwise indicated in this permit, the CEMS shall be installed, calibrated, maintained, audited and operated in accordance with the requirements of 40 CFR 60.13 and Appendices B and/or F or DEO approved procedures which are equivalent to the requirements of 40 CFR 60.13 and Appendices B and/or F. CEMS data shall be sent to a data acquisition and handling systems (DAHS) to be reduced to pounds per million Btu, one hour averages, 3 hour block averages, 24 hour rolling averages, 30 day rolling averages, and 12-month rolling averages. The span values for SO₂ and NO_x shall comply with the requirements of 40 CFR Parts 60 and 75. The permittee shall utilize monthly recorded CEMS data to calculate annual CO, SO₂, and NO_x, emissions (in tons per year) monthly as the sum of each consecutive 12-month period. Calculations shall be maintained on-site for the most recent 5-year period and shall demonstrate compliance with the emission limitations set forth in Conditions 23 through 28. The CEMS shall be used for direct compliance in determination of the SO₂ and NO_X limits as described in Conditions 23 through 28 and Condition 30. (9 VAC 5-80-890 and 9 VAC 5-80-850 F)

- 15. **Monitoring- CEMS- Carbon Monoxide (CO)** Within twelve months of the effective date of this permit, the permittee shall have installed CO CEMS meeting the design specifications of 40 CFR Part 60, Appendix B to measure and record CO, from the stacks of units C1, C2, C3, C4 and C5. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation and calibration of the device. A performance evaluation of the CO continuous monitoring system shall be conducted in accordance with 40 CFR Part 60, Appendix B. Two copies of the performance evaluation report shall be submitted to the Air Compliance Manager, NRO within forty-five days of the evaluation. A thirty day notification, prior to the demonstration of the continuous monitoring system's performance, and subsequent notifications shall be submitted to the Air Compliance Manager, NRO. The permittee shall accumulate CO data for at least six months and submit that data to the DEQ for the establishment of a permited CO emission limitation. (9 VAC 5-40-40 and 9 VAC 5-80-850 F)
- 16. **Monitoring** The permittee shall calculate monthly the emissions of PM, PM₁₀, PM_{2.5}, VOC, HCl, and HF from boilers C1, C2, C3, C4 and C5. The permittee shall calculate monthly emissions utilizing monthly boiler heat input data or monthly fuel throughput, control equipment efficiency as appropriate, and an appropriate F-factor or AP-42 emission factors in order to demonstrate compliance with the emission limitations set forth in Conditions 23 through 27. Calculated emissions shall take into account any emissions associated with startup and shutdown of the boilers. Startup and shutdown emissions shall be identified as such in any emissions calculations. (9 VAC 5-80-850 and 9 VAC 5-80-890)

- 17. **Monitoring Devices** Each fabric filter baghouse shall be equipped with a device to continuously measure and record pressure drop across the filter. The device shall be installed in an accessible location and shall be maintained by the permittee such that it is in proper working order at all times. Each monitoring device shall be installed, maintained, calibrated and operated in accordance with approved procedures which shall include, as a minimum, the manufacturer's written requirements or recommendations. Each monitoring device shall be provided with adequate access for inspection and shall be in operation when the silos are operating.

 (9 VAC 5-80-850 and 9 VAC 5-80-890 F)
- 18. **Monitoring Devices ESP** A condition assessment shall be conducted on the electrostatic precipitators daily by the permittee in order to determine whether the equipment is in proper operating condition. The details of the condition assessment shall be arranged with the Air Compliance Manager of the NRO. The permittee shall maintain a record of each assessment on-site or in a data base accessible from the PRGS for the most recent 5-year period. Records shall include the date and the time of the assessment, and any findings or corrective actions taken.(9 VAC 5-80-850 and 9 VAC 5-80-890 F)
- 19. **Monitoring Device Observation -** For the purpose of this permit, normal business hours shall be considered to be from 8:00 AM to 5:00 PM Monday through Friday. Nothing contained here in shall make an inspection time unreasonable during an emergency.
 - a. To ensure good performance, each monitoring device used to continuously measure pressure drop across the fabric filters shall record monitored data on a continuous basis within the Control Room of the PRGS.
 - b. At least once per daylight shift, an observation of the presence of visible emissions from each fabric filter baghouse shall be made.
 - c. If visible emissions are observed and are greater than 10%, the permittee shall take immediate corrective action such that the fabric filter baghouses operate with emissions less than 10%.
 - d. In the event that visible emissions greater than 10% are observed from the bottom ash silo, a visible emission evaluation (VEE) in accordance with 40 CFR 60, Appendix A, Method 9, shall be performed to assure visible emissions from the fabric filter baghouse do not exceed 10% opacity.
 - i. The VEE shall be conducted for a minimum of six minutes.
 - ii. If any two consecutive 15 second observations exceed 10% opacity, the VEE shall be conducted for a total of sixty minutes.
 - iii. If compliance is not demonstrated by the one hour VEE, immediate corrective action shall be taken such that the fabric filter baghouse resumes operation with visible emissions of 10% or less.

- e. The permittee shall maintain an observation log on-site or in a data base accessible from the PRGS during normal business hours, as defined above, for the most recent 5-year period to demonstrate compliance. The log shall include the date and the time of the observations, whether or not there were any visible emissions, any VEE recordings, and any necessary corrective action.
- f. The continuously recorded measurements of the pressure drop shall be maintained on-site or in a data base accessible from the PRGS during normal business hours, as defined above, for the most recent 5-year period and shall be made available for inspection.

 (9 VAC 5-80-850 and 9 VAC 5-80-890 F)

OPERATING LIMITATIONS

- 20. **Fuel** The approved fuels for boilers C1, C2, C3, C4 and C5 are bituminous coal and distillate oil. A change in the fuel may require a permit to modify and operate. (9 VAC 5-80-850)
- 21. **Fuel** The coal and distillate oil shall meet the specifications below:

COAL:

Minimum heat content: 8,500 Btu/lb HHV as determined by ASTM D2015, D3286, or a DEQ-approved equivalent method.

The sulfur content on a per shipment basis shall be between 0.65% and 1.2% and the annual average sulfur content shall not exceed 1.0%, both sulfur contents shall be determined by ASTM D3177, D4239, or a DEQ-approved equivalent method.

Maximum ash content per shipment: 11.0% as determined by ASTM D3174, or a DEQ-approved equivalent method.

DISTILLATE OIL which meets the ASTM D396 specification for numbers 1 or 2 fuel oil: Maximum sulfur content per shipment:

(9 VAC 5-80-850)

- 22. **Fuel Certification** The permittee shall obtain a certification from the fuel supplier with each shipment of coal and distillate oil. Each fuel supplier certification shall include the following:
 - a. The name of the fuel supplier or third party independent laboratory;
 - b. The date on which the coal was shipped or distillate oil was received;
 - c. The quantity of coal or distillate oil delivered in the shipment;
 - d. A statement that the distillate oil complies with the American Society for Testing and Materials specifications (ASTM D396) for numbers 1 and 2 fuel oil;

- e. The sulfur content of the coal or distillate oil;
- f. Documentation of sampling of the coal or distillate oil indicating the location of the fuel when the sample was taken and;
- g. The methods used to determine the sulfur and ash contents of the coal;

Fuel sampling and analysis meeting appropriate ASTM standards, independent of that used for certification, as may be periodically required or conducted by DEQ, may be used to determine compliance with the fuel specifications stipulated in Condition 21. The permittee may propose an alternate method of demonstrating compliance with the fuel sulfur requirements of this section. Exceedance of these specifications may be considered credible evidence of the exceedance of emission limits.



$\underline{EMISSION\ LIMITS}- The\ following\ emissions\ limits\ become\ effective\ upon\ issuance\ of\ this\ permit.$

23. **Process Emission Limits** - Emissions from the operation of the boiler C1 shall not exceed the limits specified below:

Pollutant	lbs/MMBtu	lbs/MMBtu	lbs/Hour	lbs/Day
ronutant			ibs/Hour	•
	(unless noted	24 hr block avg		24 hr block avg
	otherwise)			
Particulate Matter				
(PM) including	0.055	0.055	57.92	1,389.96
condensable PM	3 hr block avg			
PM-10				
including		0.055	57.92	1,389.96
condensable PM-	0.055			
10	3 hr block avg			
PM-2.5 including				
condensable PM-	0.055	0.055	57.92	1389.96
2.5	3 hr block avg			
Sulfur Dioxides	0.99		1,042.47	
(SO_2)	3 hr block avg	0.99	3 hr block avg	25,019.28
Oxides of Nitrogen	0.32		336.96	
(as NO ₂)	30 day rolling		30 day rolling	
	avg		avg	
Carbon Monoxide				
(CO)	680.90 ppmv		714.93	
	3 hr avg		30 day rolling	
			avg	
Volatile Organic				
Compounds (VOC)			4.21	
Hydrogen Chloride	0.021		22.11	
Hydrogen Fluoride	0.0076		8.00	

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Conditions 14 and 16. This Condition does not relieve the requirement to comply with the operating scenario limits in Condition 28.

24. **Process Emission Limits** - Emissions from the operation of the boiler C2 shall not exceed the limits specified below:

Pollutant	lbs/MMBtu	lb/MMBtu 24 hr block avg	lbs/Hour	lbs/Day 24 hr block avg
Particulate Matter		21 m block avg		21 III block avg
(PM) including	0.055	0.055	56.60	1,358.28
condensable PM	3 hr block avg			,
PM-10				
including condensable	0.055	0.055	56.60	1,358.28
PM-10	3 hr block avg			
PM-2.5 including				
condensable PM-2.5	0.055	0.055	56.60	1,358.28
	3 hr block avg			
Sulfur Dioxides (SO ₂)	1.02	0.90	1,049.58	22,226.40
	3 hr block avg		3 hr block avg	▼
Oxides of Nitrogen (as	0.32		329.28	
NO_2	30 day rolling		30 day rolling	
	avg		avg	
Carbon Monoxide				
(CO)	688.60 ppmv		732.99	
	3 hr avg		30 day rolling	
			avg	
Volatile Organic				
Compounds (VOC)			4.12	
Hydrogen Chloride	0.021		21.61	
Hydrogen Fluoride	0.0076		7.82	

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Conditions 14 and 16. This Condition does not relieve the requirement to comply with the operating scenario limits in Condition 28.

25. **Process Emission Limits** - Emissions from the operation of the boiler C3 shall not exceed the limits specified below:

Pollutant	lbs/MMBtu	lb/MMBtu 24 hr block avg	lbs/Hour	lbs/Day 24 hr block avg
Particulate Matter		24 III block avg		24 III block avg
(PM) including	0.055	0.055	55.99	1,343.76
condensable PM	3 hr block avg			,
PM-10				
including condensable	0.055	0.055	55.99	1,343.76
PM-10	3 hr block avg			
PM-2.5 including				
condensable PM-2.5	0.055	0.055	55.99	1,343.76
	3 hr block avg			
Sulfur Dioxides (SO ₂)	0.80	0.66	814.40	16,125.12
	3 hr block avg		3 hr block avg	
Oxides of Nitrogen (as	0.32		325.76	
NO_2)	30 day rolling		30 day rolling	
	avg		avg	
Carbon Monoxide				
(CO)	1,040.00 ppmv		1,033.67	
	3 hr avg		30 day rolling	
			avg	
Volatile Organic				
Compounds (VOC)			4.07	
Hydrogen Chloride	0.021		21.38	
Hydrogen Fluoride	0.0076		7.74	

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Conditions 14 and 16. This Condition does not relieve the requirement to comply with the operating scenario limits in Condition 28.

26. **Process Emission Limits** - Emissions from the operation of the boiler C4 shall not exceed the limits specified below:

Pollutant	lbs/MMBtu	lbs/MMBtu	lbs/Hour	lbs/Day
		24 hr block avg		24 hr block avg
Particulate Matter				
(PM) including	0.055	0.055	59.79	1,434.84
condensable PM	3 hr block avg			
PM-10				
including condensable	0.055	0.055	59.79	1,434.84
PM-10	3 hr block avg			
PM-2.5 including				
condensable PM-2.5	0.055	0.055	59.79	1,434.84
	3 hr block avg			
Sulfur Dioxides (SO ₂)	0.77	0.60	836.99	15,652.80
	3 hr block avg		3 hr block avg	
Oxides of Nitrogen (as	0.32		347.84	
NO_2)	30 day rolling		30 day rolling	
	avg		avg	
Carbon Monoxide				
(CO)	1040.00 ppmv		994.79	
	3 hr avg		30 day rolling	
			avg	
Volatile Organic				
Compounds (VOC)			4.35	
Hydrogen Chloride	0.021		22.83	
Hydrogen Fluoride	0.0076	- 4	8.26	

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Conditions 14 and 16. This Condition does not relieve the requirement to comply with the operating scenario limits in Condition 28.

27. **Process Emission Limits** - Emissions from the operation of the boiler C5 shall not exceed the limits specified below:

Pollutant	lbs/MMBtu	lbs/MM Btu	lbs/Hour	lbs/Day
		24 hr block		24 hr block avg
		avg		
Particulate Matter				
(PM) including	0.055	0.055	60.89	1,461.24
condensable PM	3 hr block avg			
PM-10				
including condensable	0.055	0.055	60.89	1,461.24
PM-10	3 hr block avg			
PM-2.5 including				
condensable PM-2.5	0.055	0.055	60.89	1,461.24
	3 hr block avg			
Sulfur Dioxides (SO ₂)	0.70	0.53	774.90	14,081.04
	3 hr block avg		3 hr block avg	
Oxides of Nitrogen (as	0.32		354.24	
NO_2)	30 day rolling		30 day rolling	
	avg		avg	
Carbon Monoxide				
(CO)	1040.00 ppmv		968.75	
	3 hr avg		30 day rolling	
			avg	
Volatile Organic				
Compounds (VOC)			4.43	_
Hydrogen Chloride	0.021	4	23.25	
Hydrogen Fluoride	0.0076		8.41	

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Conditions 14 and 16. This Condition does not relieve the requirement to comply with the operating scenario limits in Condition 28.

Lb/MM Btu

Lb/Day

28. Process Emission Limits – Multiple Operating Scenarios - Emissions for the operation of combination unit operations shall not exceed the limits specified below.

The operating scenarios listed below may be expanded as Mirant has suggested that there are additional scenarios that they would like to propose that will be NAAQS complaint and will provide the facility with additional flexibility.

Max value for any case

Operating	SO ₂ 3 hr block	SO ₂ 3 hr bloc		_
Scenario	avg	avg	block av	
	lbs/MMBtu per	lbs/Hr	lbs/MMB	tu lbs/Day
	unit			
2 cycling	0.50	1,041.00	0.48	23,984.64
2 base	0.37	811.78	0.28	14,743.68
1 cycling/1 base	0.42	907.20	0.36	18,662.40
2 cycling/ 1 base	0.29	924.81	0.27	20,664.72
1 cycling/ 2 base	0.27	876.69	0.23	17,923.44
3 base	0.25	803.00	0.21	16,188.48
				<u> </u>
Operating	PM 1 hr avg	PM 1 hr avg	PM 24 hr block	PM 24 hr block
Scenario	Lb/MM Btu	Lb/Hr	avg	avg
			Lb/MM Btu	Lb/Day
Max value for	0.055	178.59	0.055	4,286.04
any case				
				·
Operating	PM ₁₀ 1 hr avg	PM_{10} 1 hr	PM ₁₀ 24 hr bloc	ek PM ₁₀ 24 hr block
Scenario	Lb/MM Btu	average	avg	avg
		Lb/Hr	Lb/MM Btu	Lb/Day
Max value for	0.055	178.59	0.055	4,286.04
any case				
		>		
Operating	PM _{2.5} 1 hr average	PM _{2.5} 1 hr avg	PM _{2.5} 24 hr bloc	ek PM _{2.5} 24 hr
Scenario	Lb/MM Btu	Lb/Hr	avg	block avg
			Lb/MM Btu	Lb/Day
Max value for	0.055	178.59	0.055	4,286.04
any case				
				<u>.</u>
Operating	NOx 1 hr avg	NOx 1 hr avg	NOx 24 hr	NOx 24 hr
Scenario	Lb/MM Btu (30-	Lb/Hr (30 day	average	average
	1 4 44			

rolling avg) 1,039.04

day rolling avg.)

0.32

Operating	CO 1 hr avg	CO1 hr avg	CO 24 hr block	CO 24 hr block
Scenario	Lb/MM Btu	Lb/Hr	avg	avg
			Lb/MM Btu	Lb/Day
Max value for		2,997.20		
any case				

Operating	HCl 1 hr avg	HCl 1 hr avg	HCl 24 hr	HCl 24 hr avg
Scenario	Lb/MM Btu	Lb/Hr	average	Lb/Day
			Lb/MM Btu	-
Max value for	0.021	68.19		
any case				

Operating	HF 1 hr avg	HF1 hr avg	HF 24 hr avg	HF 24 hr avg
Scenario	Lb/MM Btu	Lb/Hr	Lb/MM Btu	Lb/Day
Max value for	0.0076	24.68		
any case				¥

These tables were developed using the worst case scenario of operating combination of units which would exhibit the highest ambient impact.

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Conditions 14 and 16.

(9 VAC 5-80-850)

29. **Emission Calculations** – The permittee shall calculate emissions of PM, PM-10, PM-2.5, HCl, HF, and VOC in tons per year from boilers C1, C2, C3, C4 and C5. The permittee shall calculate annual emissions monthly as the sum of each consecutive 12-month period utilizing monthly boiler heat input data or monthly fuel throughput, control equipment efficiency, and appropriate F-factors or AP-42 emission factors in order to demonstrate compliance with the emission limitations set forth in Conditions 30. Calculated emissions shall take into account any emissions associated with startup and shutdown of the boilers. Startup and shutdown emissions shall be identified as such in any emissions calculations.

(9 VAC 5-80-850 and 9 VAC 5-80-890)

30. **Facility wide Emission Limits** - Total emissions from boilers C1, C2, C3, C4, and C5 combined shall not exceed the limits specified below:

	Tons/Year
Particulate Matter (PM) including	
condensable PM	562
PM-10	
including condensable PM-10	377
PM-2.5 including condensable PM-	
2.5	163
Sulfur Dioxides (SO ₂)	3813
Oxides of Nitrogen (as NO ₂)	3700
Oxides of Nitrogen (as NO ₂)	
(Ozone Season until 12/31/08)	1600
Carbon Monoxide (CO)	215
Volatile Organic Compounds (VOC)	26
Hydrogen Chloride (HCl)	100
Hydrogen Fluoride (HF)	36.22

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Conditions 14 and 29.

- 31. **Visible Emissions Limit Bottom Ash Silo -** Visible emissions from the bottom ash silo shall not exceed 10% opacity as determined by 40 CFR Part 60, Appendix A, Method 9. (9 VAC 5-80-850)
- 32. Visible Emission Limit Visible emissions from the boilers C1, C2, C3, C4 and C5 shall not exceed 20 percent opacity except during one six-minute period in any one hour in which visible emissions shall not exceed 30 percent opacity as determined by the EPA Method 9 (reference 40 CFR 60, Appendix A). The COMS may be used to satisfy the visible emission evaluation requirement in lieu of 40 CFR, Part 60, Appendix A, Method 9. In the event that the COMS is used in lieu of a 40 CFR, Part 60, Appendix A, Method 9 evaluation, the reported data shall include averages of all six minute continuous periods within the reported period and within the duration of any mass emission performance tests being conducted. It is the responsibility of the permittee to demonstrate that the monitoring system has met the requirements of the applicable performance specification defined in 40 CFR Part 60, Appendix B that the monitoring system has been properly maintained and operated, and that the resulting data has not been altered in any way. In the event that the COMS data indicates compliance for a period during which Method 9 data indicates non-compliance, the Method 9 data may be used to determine compliance with the visible emission limit. This condition applies at all times except during startup, shutdown, and malfunction. (9 VAC 5-80-850 and §10.1-1307.3.B)

COMPLIANCE DETERMINATION

- 33. Stack Test Performance tests shall be conducted for PM, PM₁₀, PM_{2.5}, HCl, and HF from C1, C2, C3, C4 and C5 using appropriate and approved 40 CFR Part 60 Appendix A reference methods to determine compliance with the emission standards contained in Conditions 23 through 27. CO shall be tested for the purpose of establishing a baseline for future emissions limitation determination. Additionally, the hot and cold side ESP efficiencies shall be determined during this performance testing and the secondary volts and current shall be recorded as the base line for monitoring the ESP operation. If the permittee determines that it is in the best interest of good air pollution control practices to utilize a lower sulfur coal than that required in condition 21, a test may be conducted to demonstrate the rate of dry sorbent injection necessary to provide the appropriate level of HCl and HF reduction to ensure compliance with the Significant Ambient Air Concentration values. The tests shall be performed and demonstrate compliance within 180 days after the effective date of this permit. Tests shall be conducted and reported and data reduced as set forth in 9 VAC 5-40-30 and 9 VAC 5-60-30. The details of the tests are to be arranged with the Air Compliance Manager, NRO. The permittee shall submit a test protocol at least 30 days prior to testing. One paper copy and two electronic copies on removable media of the test results shall be submitted to the Air Compliance Manager, NRO within sixty days after test completion and shall conform to the test report format enclosed with this permit. (9 VAC 5-40-30, 9 VAC 5-60-30, and 9 VAC 5-80-880 A)
- 34. Visible Emissions Evaluation Concurrently with the initial performance tests, and during the Method 5 compliance demonstration test, a Visible Emission Evaluations (VEE) in accordance with 40 CFR Part 60, Appendix A, Method 9, shall be conducted by the permittee on each stack, C1, C2, C3, C4 and C5. Each test shall consist of 30 sets of 24 consecutive observations (at 15 second intervals) to yield a six minute average. The details of the tests are to be arranged with the Air Compliance Manager, NRO of the DEQ. The permittee shall submit a test protocol at least thirty days prior to testing. The evaluation shall be performed, during compliance demonstration testing required in Condition 33. Should conditions prevent concurrent opacity observations, the Air Compliance Manager, NRO of the DEQ shall be notified in writing, within seven days, and visible emissions testing shall be rescheduled within thirty days. Rescheduled testing shall be conducted under the same conditions (as possible) as the initial performance tests. The continuous opacity monitoring system may be used to satisfy the visible emission evaluation requirement in lieu of 40 CFR, Part 60, Appendix A, Method 9. In the event that the COMS is used in lieu of a 40 CFR, Part 60, Appendix A, Method 9 evaluation, the reported data shall include averages of all six minute continuous periods within the reported period and within the duration of any mass emission performance tests being conducted. One copy of the test result shall be submitted to the Air Compliance Manager, NRO of the DEQ within sixty days after test completion and shall conform to the test report format enclosed with this permit. (9 VAC 5-40-30 and 9 VAC 5-80-880 A)
- 35. **CEMS/COMS Performance Evaluations -** Performance evaluations of the continuous monitoring systems shall be conducted in accordance with 40 CFR Part 60, Appendix B, and may take place during any performance tests conducted in accordance with 9 VAC 5-40-30 or within thirty days

thereafter or as directed by the DEQ. Two copies of the performance evaluations report shall be submitted to the Air Compliance Manager, NRO within forty-five days of the evaluation. The continuous monitoring systems shall be installed and operational prior to conducting initial performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation and calibration of the device. A thirty day notification, prior to the demonstration of continuous monitoring system's performance, and subsequent notifications shall be submitted to the Air Compliance Manager, NRO.

(9 VAC 5-40-40)

36. **CEMS/COMS Quality Control Program -** A CEMS/COMS quality control program which meets the requirements of 40 CFR 60.13 and Appendix B and/or F and 40 CFR Part 75 shall be implemented for all continuous monitoring systems except that Relative Accuracy Test Audits (RATA) may be required less frequently if approved by DEQ. (9 VAC 5-40-40)

CONTINUED COMPLIANCE

37. Annual Compliance Testing

- a. The permittee shall demonstrate compliance on an annual basis with the limits in Conditions 23 through 28 utilizing appropriate 40 CFR Part 60, Appendix A reference test methods in the testing of PM-10, PM-2.5, HCl, HF, and Hg.
- b. The hot and cold side ESP particulate removal effectiveness shall be determined during this performance testing and the secondary volts and current shall be recorded as the base line for continued monitoring of the ESP operation.
- c. These tests shall be performed annually on two base load units and one cycling unit. Testing performed the next year shall be on at least two units that were not tested the previous year.
- d. These tests shall be arranged with the Air Compliance Manager, NRO.
- e. Tests shall be conducted and reported and data reduced as set forth in 9 VAC 5-40-30 and 9 VAC 5-60-30.
- f. The permittee shall submit a test protocol at least 30 days prior to testing.
- g. One paper copy of the test results and two electronic copies, on removable media, of the test results shall be submitted to the Air Compliance Manager, NRO within sixty days after test completion and shall conform to the test report format enclosed with this permit.
- (9 VAC 5-40-30 and 9 VAC 5-60-30)

RECORDS

- 38. **On Site Records** The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. These records shall be maintained on site or in a data base accessible from the PRGS. The content and format of such records shall be arranged with the Air Compliance Manager, NRO. These records shall include, but are not limited to:
 - a. All fuel supplier certifications.
 - b. Annual emissions calculations for PM, PM-10, PM-2.5, HCl, HF, and VOC's in tons per year from the boilers using calculation methods approved by the Air Compliance Manager NRO to verify compliance with the ton/yr emissions limitations in Condition 30.
 - c. CEMS and COMS maintenance and calibration records including but not limited to continuous monitoring system quarterly gas audits and daily continuous monitoring system calibrations and calibration checks, percent operating time, and excess emissions.
 - d. All recorded CEMS and COMS data necessary to demonstrate compliance with the requirements of Conditions 14 and 16 and with the emission limitations outlined in Conditions 23 through 27.
 - e. Any required visible emissions evaluations (VEEs) and visible emission evaluation logbook data.
 - f. Operation and control device monitoring records for the electrostatic precipitators and fabric filters as required in Conditions 11, 17, 18 and 19.
 - g. All records of compliance demonstration, CEM certifications and CEM Relative Accuracy Audit Tests.
 - h. Scheduled and unscheduled maintenance and operator training.
 - i. The annual average sulfur content of coal shipped to the facility shall be calculated monthly as the average of each consecutive twelve month period.
 - j. Daily records of the operating scenarios under which the facility operated for each calendar day in a format approved by the Air Compliance Manager, NRO.

These records shall be available for inspection by the DEQ during normal business hours and shall be considered to be from 8:00 AM to 5:00 PM Monday through Friday and shall be current for the most recent five years. Nothing contained here in shall make an inspection time unreasonable during an emergency.

(9 VAC 5-80-890 A.)

REPORTING REQUIREMENTS

- 39. **Quarterly Reports for Continuous Monitoring Systems -** The permittee shall furnish written reports to the Air Compliance Manager NRO of excess emissions from any process monitored by a continuous monitoring system (COMS/CEMS) on a quarterly basis, postmarked no later than the 30th day following the end of the calendar quarter. These reports shall include, but are not limited to the following information:
 - a. The magnitude of excess emissions, any conversion factors used in the calculation of excess emissions, and the date and time of commencement and completion of each period of excess emissions;
 - b. Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the process, the nature and cause of the malfunction (if known), the corrective action taken or preventative measures adopted;
 - c. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments; and
 - d. When no excess emissions have occurred or the continuous monitoring systems have not been inoperative, repaired or adjusted, such information shall be stated in that report.
 (9 VAC 5-40-50)
- 40. **Semi-Annual Report** The permittee shall submit reports to the NRO within sixty days after the end of each semi-annual period. The semi-annual periods are defined as January 1st through June 30th and July 1st through December 31st of each year. The permittee may submit the reports in electronic format as approved by the Air Compliance Manager, NRO, within thirty days after the end of each semi-annual period. Each semi-annual report shall include the dates included in the semi-annual period and the following:
 - a. For SO₂ CO and NO_x emissions and continuous emissions monitoring:
 - i. Each 30-day average emission rate in lbs/MMBtu;
 - ii. Identification of days for which CO, SO₂, NO_x, either O₂, or CO₂ data have not been obtained by an approved method for at least 75 percent of operating hours, reasons for not obtaining sufficient data and corrective actions taken;
 - iii. Identification of any time intervals when emissions data have been excluded from the calculation of average emission rates, justification for excluding data and a description of corrective action taken if data have been excluded for periods other than when oil was not combusted in the unit;

- iv. Identification of the F-factor used in calculations, method of determination for each type of fuel combusted, and type of fuel combusted;
- v. Identification of any times when the pollutant concentration exceeded the full span of the continuous emissions monitor;
- vi. Description of any modifications to the continuous emissions monitor that could effect its ability to comply with the performance specifications under 40 CFR 60, Appendices B and/or F; and
- vii. Summary of the results of daily continuous emissions monitor drift tests and semi-annual accuracy assessments as required by 40 CFR 60, Appendix F, Procedure 1.
- b. For visible emissions and opacity monitoring, the permittee shall report all excess opacity and the percentage of operating hours for which opacity monitoring data have not been obtained. If no excess opacity occurred or opacity monitoring data were obtained for all operating hours during the reporting period, the semi-annual report shall contain a statement as such. All semi-annual opacity monitoring reports shall conform to the Opacity Monitoring Report Format enclosed with this permit.

(9 VAC 5-170-160 and 9 VAC 5-40-50)

GENERAL CONDITIONS

- 41. **Right of Entry** The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:
 - a. To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;
 - b. To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
 - c. To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and
 - d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency. (9 VAC 5-170-130)

42. **Maintenance/Operating Procedures** – At all times, including periods of start-up, shutdown, soot blowing, and malfunction, the permittee shall, to the extent practicable, maintain and operate the

affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take the following measures in order to minimize the duration and frequency of excess emissions, with respect to boilers C1, C2, C3, C4 and C5 and electrostatic precipitators HSEP1, HSEP2, HSEP3, HSEP4, and HSEP5 and CSEP1, CSEP2, CSEP3, CSEP4, and CSEP5, and dry sorbent (Sodium sesquicarbonate) injection system:

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain a reasonable inventory of spare parts.
- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, at a minimum.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such equipment. The permittee shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.

Records of maintenance and training shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request. (9 VAC 5-40-20 E and 9 VAC 5-80-890)

- 43. **Record of Malfunctions** The permittee shall maintain records of the occurrence and duration of any bypass, malfunction, shutdown or failure of the facility or its associated air pollution control equipment that results in excess emissions for more than one hour or opacity in excess of 20% for any two consecutive, 6 minute periods. Records shall include the date, time, duration, description (emission unit, pollutant affected, cause), corrective action, preventive measures taken and name of person generating the record. (9VAC 5-20-180 J)
- 44. **Notification for Facility or Control Equipment Malfunction** The permittee shall furnish notification to the Air Compliance Manager NRO of malfunctions of the affected facility or related air pollution control equipment that may cause excess emissions for more than one hour, by facsimile transmission, telephone or telegraph or other electronic means acceptable to the DEQ. Such notification shall be made as soon as practicable but no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within two weeks of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Air Compliance Manager NRO. (9 VAC 5-20-180 C)

- 45. Exceedance of Ambient Air Quality Standard Regardless of any other provision of this section, the owner of any facility subject to the Regulations for the Control and Abatement of Air Pollution shall, upon request of the board, reduce the level of operation at the facility if the board determines that this is necessary to prevent a violation of any primary ambient air quality standard. Under worst case conditions, the board may order that the owner shut down the facility, if there is no other method of operation to avoid a violation of the primary ambient air quality standard. The board reserves the right to prescribe the method of determining if a facility will cause such a violation. In such cases, the facility shall not be returned to operation until it and the associated air pollution control equipment are able to operate without violation of any primary ambient air quality standard. (9 VAC 5-20-180 I)
- 46. **Change of Ownership** In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current permit issued to the previous owner. The new owner shall notify the NRO of the change of ownership within 30 days of the transfer. (9 VAC 5-80-940)
- 47. **Permit Copy** The permittee shall keep a copy of this permit on the premises of the facility to which it applies.
 (9 VAC 5-170-180)